

K.SIVAGURUNATHAN

Approved Panel Engineer

Class I A

(By The District Collector, Kanyakumari Dist.)

Office	04652 - 226804
Resi	04652 - 245666
Mobile	94431 68080
Mail ID	ksagn51@gmail.com

GANESH ASSOCIATES 1, HINDU COLLEGE ROAD, CHETTIKULAM JUNCTION, KOTTAR, NAGERCOIL - 629 002.

KS : SSC No : 2293 / 22

30 11 22

STATEMENT ACCOMPANYING FORM A

1. Door No. of the building	I/III-3 (MAIN BLOCK) R Sy No. 360 / 1, 2
2. Location of the building	MOUNT LITERA ZEE SCHOOL Thillai Avenue Koondupalam North Mylaudy KK Dist.
3. Year of construction	2013 - 14
4. Approx. constrn.cost as per current rates	Rs. 30 00 000.00
5. Purpose for which building is being used/ proposed to be used	School building
6. Purpose for which building has hitherto been used	School building
7. Details of construction of the building	
i. Foundation	RCC isolated column footing
ii. Basement	RCC isolated column footing
iii. Super Structure	RCC frame & BW in CM
iv. Floor	PCC & marble / ceramic floor finish
v. Roof	RCC slab & beam
8. Period for which licence is required	01 01 23 to 31 12 25 (3 years)
9. No. of persons to be accommodated	1000 Nos



K.SIVAGURUNATHAN
Approved Panel Engineer

Date: 30 11 22


Certified that no addition or alteration has been made to the existing building or portion of the building for which this application has been made. I undertake to obtain fresh licence , in case addition/alteration is made to the existing building of portion of the building. I also undertake to obtain fresh licence, if the purpose for which the licence was granted for the use of the building originally is changed or altered subsequently.

Date:

S. D. Dyal

N. S. S. S.
SIGNATURE OF THE BUILDING OWNER

PRINCIPAL
MOUNT LITERA ZEE SCHOOL MYLAUDY
CBSE AFFILIATION No: 1930787
KANYAKUMARI - 629 403



SECRETARY
Mount Litera Zee School
Mylaudy - 629403

K.SIVAGURUNATHAN

Approved Panel Engineer

Class I A

(By The District Collector, Kanyakumari Dist.)

Office	04652 - 226804
Resi	04652 - 245666
Mobile	94431 68080
Mail ID	kagn51@gmail.com

GANESH ASSOCIATES 1, HINDU COLLEGE ROAD, CHETTIKULAM JUNCTION, KOTTAR, NAGERCOIL - 629 002.

KS : SSC No : 2293 / 22

30 11 22

FORM - B & C

Form of CERTIFICATE OF STRUCTURAL STABILITY under sub-section 4 of the Madras Public Buildings (Licensing) Act 1965, (Madras Act 13 of 1965) referred to in Rule 4 of the Madras Public Buildings (Licensing) Rules 1966.

I certify that I have inspected the buildings mentioned in the statement and furnish below its technical features :

1. FOUNDATION :

- | | | | | |
|----|--|---|-----------|-----------|
| 1. | Depth below ground level | = | 2.0 | m average |
| 2. | Nature of soil met with at foundation level | = | Hard Soil | |
| 3. | Pressure at Foundation | = | 16.8 | t/sqm |
| 4. | Probable S B Capacity of the strata met with at foundation | = | 30.0 | t/sqm |

2. SUPERSTRUCTURE :

- | | | | | |
|----|---|---|------|-------|
| 1. | Maximum stress in the most critical section of masonry and concrete | = | 19.2 | t/sqm |
| 2. | Nature of masonry and concrete and its safe permissible stresses | = | 40.0 | t/sqm |

The structural soundness of the building has been verified by me with reference to ISI loading Standard 875 (Latest version) and other relevant IS CODE OF PRACTICE and I declare that the building is structurally sound to be used as Public Building for the purpose noted in the statement, furnished.

A licence may be granted for the period from 01 01 23 to 31 12 25 (3 years)


Date: 30 11 22

S. D. Path



K. SIVAGURUNATHAN
Approved Panel Engineer

PRINCIPAL
MOUNT LITERA ZEE SCHOOL MYLAUDY
CBSE AFFILIATION No: 1930787
KANYAKUMARI - 629 403



Sangam
SECRETARY
Mount Litera Zee School
Mylaudy - 629403

K.SIVAGURUNATHAN

Approved Panel Engineer Class I A

(By The District Collector, Kanyakumari Dist.)

Office	04652 - 226804
Resi	04652 - 245666
Mobile	94431 68080
Mail ID	ksgn51@gmail.com

GANESH ASSOCIATES 1, HINDU COLLEGE ROAD, CHETTIKULAM JUNCTION, KOTTAR, NAGERCOIL - 629 002.

KS : SSC No : 2293 / 22

30 11 22

STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

Location of the building	Age of bldg	No. of storeys	Short Description	Certified purpose	Certified period	No. of persons to be accommodated
1/III-3 (MAIN BLOCK)	9	GF + 1	RCC framed	School building	Three	1000
MOUNT LITERA ZEE SCHOOL	years	only	structure		Years	Nos.
Thillai Avenue Koondupalam North Mylaudy KK Dist.			RCC slab		Construction is still on in the first floor.	



DECLARATION

I, **K.SIVAGURUNATHAN** do hereby declare that I possess the qualification and experience stipulated in the table of Rule II of Madras Public Buildings (Licensing) Act for issuing the STRUCTURAL SOUNDNESS CERTIFICATE of the building covered by this certificate.

S. Dhyani

PRINCIPAL

MOUNT LITERA ZEE SCHOOL MYLAUDY
CBSE AFFILIATION No: 1930787
KANYAKUMARI - 629 403



K. SIVAGURUNATHAN
Approved Panel Engineer

SECRETARY

Mount Litera Zee School
Mylaudy - 629403

Date: 30 11 22